



# NMSU FIRE DEPARTMENT FIRE PUMPS QUARTERLY INSPECTION



This form covers a 1-year period. Year: \_\_\_\_\_

Inspector: \_\_\_\_\_

System: \_\_\_\_\_

Location: \_\_\_\_\_

Y=Satisfactory N=Unsatisfactory (explain on reverse)      N/A = Not applicable

**Monthly**

Date												
Inspector												
Check crankcase breather on diesel pump for proper operation.												
Clean water strainer in cooling system for diesel fire pump.												
Check exhaust system insulation for integrity.												
Check exhaust system clearance to combustibles to prevent fire hazard.												
Check battery terminals to ensure they are clean and tight.												
Check electrical wiring for chafing where subject to movement.												
Check operation of safety devices and alarms (semi-annually).												

Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

See Main System Record of Completion for additional information, certifications, and approvals. Attach additional sheets, data, or calculations as necessary to provide a complete record.

Form Completion Date: \_\_\_\_\_

Supplemental Pages Attached: \_\_\_\_\_